

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No. 64/RWS

Dated: 23.04.2024

It is certified that an inspection team headed by the Assistant Engineer, R.W.S. Birbhum Sub – Division P.H.E Dte. Suri From P.H.E. Dte. Complex, S.P. More inspected the **GITANJALI PUBLIC SCHOOL, DAIKOTA, SAINTHIA, BIRBHUM on 23.04.2024** and found that the **GITANJALI PUBLIC SCHOOL, DAIKOTA, SAINTHIA, BIRBHUM** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of **ONE YEAR (01)**



*Assistant Engineer*  
R.W.S. Birb-Sub-Divn.  
P.H.E. Dte.

Signature with Seal: \_\_\_\_\_

Name: MADHAB KUMAR SINGHA.

Designation: Assistant Engineer, R.W.S. Birbhum  
Sub – Division P.H.E

Name & Address of the Office / Department:  
P.H.E. Dte. Complex, S.P. More, Suri, Birbhum,  
PIN – 731101, West Bengal

To,  
**GITANJALI PUBLIC SCHOOL**  
**DAIKOTA, DERIAPUR, SAINTHIA,**  
**731234, BIRBHUM, WEST BENGAL**

Government of West Bengal  
Office of the Executive Engineer  
Birbhum Division, P.H.Engineering Dte.  
P.H.E. Dte. Complex, S.P. More, Suri, Birbhum.  
THE DISTRICT WATER TESTING LABORATORY

Quality Parameters	pH	Iron(Fe)	Fluoride	Hardness	Turbidity	TDS	Manganese	T.C	F.C
Unit of Measurement	N/A	mg/l	mg/l	mg/l	NTU	mg/l	mg/l	CFU/ 100ml	CFU/ 100ml
BIS Permissible Limit	8.5	1	1.5	600	5	2000	0.3	0	0
BIS Desirable Limit	6.5	0.3	1.0	200	1	500	0.1	0	0

Sl. No	Water Source Location	Reference (if any)	Date of Collection	Test Completion Date	pH	Iron (mg/l)	Fluoride (mg/l)	Hardness (mg/l)	Turbidity NTU	TDS (mg/l)	Manganese (mg/l)	T.C CFU/100ml	F.C CFU/100ml
1	GITANJALI PUBLIC SCHOOL DAIKOTA, DERIAPUR, SAINTHIA, BIRBHUM.		16.04.2023	23.04.2023	6.67	0.2	0.226	84	0.07	202	0.02	0	0

*[Signature]* 23/4/24  
Bacteriologist  
Birbhum Division  
P.H.E. Dte.  
**Bacteriologist**  
District W.T. Laboratory  
Birbhum Division, PHE Dte  
Suri, Birbhum

*[Signature]* 23/4/24  
Chemist  
Birbhum Division  
P.H.E. Dte.  
**Chemist**  
District W.T. Laboratory  
Birbhum Division, P.H.E Dte  
Suri, Birbhum

*[Signature]* 23/04/24  
Junior Engineer  
Birbhum Division  
P.H.E Dte.  
**Junior Engineer**  
Birbhum Division, P.H.E Dte  
Suri, Birbhum

*[Signature]* 23/4/24  
Assistant Engineer (RWS)  
Birbhum Sub-Division  
Birbhum Division  
**Assistant Engineer**  
R.W.S. Birbhum Sub-Divn  
P.H.E Dte. Suri